

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 4075-0035:109 Page 1 of 1

**CATEGORY:** Glazing-Window/Door Assemblies

**LISTING:** O'Keeffe's Inc., \*325 Newhall Street, San Francisco, CA 94124-1432  
Contact: Kevin Turner (415) 822-4222 FAX (415) 822-5222\*

**DESIGN:** Model "SUPERLITE II XL" glazing material. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 45 minutes  
Nominal 3/4" and 1" in thickness

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, classification and Warnock Hersey label.

**APPROVAL:** Listed as 45-minute fire-rated glazing material for use in wood/wood composite or steel fire doors, steel frames and aluminum frames for sidelights/transom lights/borrowed lights and door vision panels.

Opening dimensions	3/4"	1"	1"
Max. Allowable Clear View Area	2432 in <sup>2</sup>	4952 in <sup>2</sup>	2050 in <sup>2</sup>
Max. Allowable Clear View Width	70.5"	106.5"	124.25"
Max. Allowable Clear View Height	70.5"	106.5"	124.25"
Minimum Stop Depth	5/8"	5/8"	5/8"

- NOTE:** Allowances:
1. Patterns, Opaque, Tints
  2. 3/16" high x 1-1/2" wide x 3" long calcium silicate or hardwood setting blocks must be used at quarter points under the bottom edges; and 1/8" thick x 5/8" wide, closed cell foam glazing tape is required on all edges (on both faces).
  3. Exterior glazing composed of an additional laminate glazing layer with PVB acceptable, including an additional glazing panel.

\*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**